

74986-4

11/19/2012

1/29



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
WASHINGTON, D.C. 20460

OFFICE OF CHEMICAL SAFETY
AND POLLUTION PREVENTION

November 19, 2012

Mr. Jeff Thomas, CEO
Selective Micro Technologies, LLC
4449 Easton Way
Second Floor
Columbus, OH 43219

Subject: Notification per PR Notice 98-10
Product Name: **Selectroicide 21500**
EPA Registration Number: **74986-4**
Application Date: November 5, 2012
Application Receipt: November 15, 2012

Dear Mr. Thomas:

This acknowledges receipt of your Notification application, submitted under the provisions of FIFRA 3 (c) 9 and PR Notice 98-10.

Proposed Notification:

Selective Micro Technologies, LLC is submitting the following Alternate Brand Name for **EPA Reg. No. 74986-4: Selectroicide Pouch 200 MG Abridged.**

General Comments:

Based on a review of the material submitted, the following comment applies.

The Notification application is **Acceptable**. A copy of the accepted Notification is attached in your file (**EPA Reg. No. 74986-4**) for future reference.

If you have any questions or comments with regard to this Agency Letter, please contact Killian Swift via email at Swift.Killian@epa.gov or by telephone at **703-308-6346**. When you are submitting information or data in response to this Agency Letter, send a copy of this Agency Letter to accompany your follow-on submission in order to facilitate processing.

Sincerely yours,

Monisha Harris,
EPA Product Manager 32
Regulatory Management Branch II
Antimicrobials Division (7510P)

	United States Environmental Protection Agency Washington, DC 20460	<input type="checkbox"/> Registration <input type="checkbox"/> Amendment <input checked="" type="checkbox"/> Other	OPP Identifier Number
--	---	--	-----------------------

Application for Pesticide - Section I

1. Company/Product Number 74986-4	2. EPA Product Manager Ms. Monisha Harris	3. Proposed Classification <input checked="" type="checkbox"/> None <input type="checkbox"/> Restricted
4. Company/Product (Name) Selectroicide 2L200 MG Abridged, ABN for Req. 74986-4	PM# 32	
5. Name and Address of Applicant (Include ZIP Code) Selective Micro Technologies 4449 Easton Way - 2nd FL Columbus, OH 43219 <input type="checkbox"/> Check if this is a new address	6. Expedited Review. In accordance with FIFRA Section 3(c)(3) (b)(i), my product is similar or identical in composition and labeling to: EPA Reg. No. <u>N/A</u> Product Name _____	

Section - II

<input type="checkbox"/> Amendment - Explain below.	<input type="checkbox"/> Final printed labels in response to Agency letter dated _____
<input type="checkbox"/> Resubmission in response to Agency letter dated _____	<input type="checkbox"/> "Me Too" Application.
<input checked="" type="checkbox"/> Notification - Explain below.	<input type="checkbox"/> Other - Explain below.


Explanation: Use additional page(s) if necessary. (For section I and Section II.)

Adding an alternative brand name, Selectroicide 2L200MG Abridged, to product registration no. 74986-4, Selectroicide 2L500. Please see cover letter for additional information.

Section - III

1. Material This Product Will Be Packaged In:				2. Type of Container	
Child-Resistant Packaging <input type="checkbox"/> Yes* <input type="checkbox"/> No	Unit Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	Water Soluble Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Metal <input type="checkbox"/> Plastic <input type="checkbox"/> Glass <input type="checkbox"/> Paper <input type="checkbox"/> Other (Specify) _____		
* Certification must be submitted		If "Yes" Unit Packaging wgt. No. per container	If "Yes" Package wgt No. per container		
3. Location of Net Contents Information		4. Size(s) Retail Container		5. Location of Label Directions	
<input type="checkbox"/> Label <input type="checkbox"/> Container				<input type="checkbox"/> On Label <input type="checkbox"/> On Labeling accompanying product	
6. Manner in Which Label is Affixed to Product				<input type="checkbox"/> Other _____	
<input type="checkbox"/> Lithograph <input type="checkbox"/> Paper glued <input type="checkbox"/> Stenciled					

Section - IV

1. Contact Point (Complete items directly below for identification of individual to be contacted, if necessary, to process this application.)		
Name Jeff Thomas	Title CEO	Telephone No. (Include Area Code) 614.934.1239
Certification I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.		8. Date Application Received (Stamped)
2. Signature 	3. Title CEO, Selective Micro Technologies	
4. Typed Name Jeff Thomas	5. Date Nov 6, 2012	



3/24

11/5/12

Via Certified Mail

Document Processing Desk (DCI/PRD)
Office of Pesticide Programs
US Environmental Protection Agency
Room S-4900, One Potomac Yard
2777 S. Crystal Drive
Arlington, Virginia 22202

To: **Monisha Harris**
Team Leader 32
Regulatory Management Branch

Re: **Registant: Selective Micro Technologies, LLC ("SMT")**
Product: Selectrocide® 2L500 (EPA Reg. 74986-4)
Notification – Addition of an Alternate Brand Name per PR Notice 98-10

Dear Ms. Harris:

On behalf of Selective Micro Technologies, LLC ("SMT"), we are notifying EPA that Selectrocide® 2L500 will be marketed under the Alternate Brand Name (ABN) of **Selectrocide Pouch 200MG Abridged**. Enclosed is the required paperwork to support this ANB.

This notification is consistent with provisions of PR Notice 98-10 and EPA regulations at 40 C.F.R. § 152.46, and no other changes have been made to the confidential statement of formula of this product. The current proposed label is a reduced subset of the Mast Label on file. It includes recommended precautionary language per EPA letter September 4th, 2012. As a safety precaution, we also indicate on the label subset for the user to, "Please reference Master Technical Bulletin for Detailed Use Patterns and Dilution Rates." I understand that it is a violation if 18 U.S.C. § 1001 to willingly make any false statement to the EPA. I further understand that if this notification is not consistent with the terms of PR Notice 98-10 and 40 C.F.R. § 152.46, this product may be in violation of FIFRA, and I may be subject to enforcement action and penalties under sections 12 and 14 of FIFRA.

Please contact me at the above number should you have any questions regarding this notification.

Sincerely,

Mr. Jeff Thomas, Selective Micro Technologies, LLC
President and CEO

A handwritten signature in black ink that reads "Jeff Thomas".

CC: Mr. Kevin Dearwester, Selective Micro Technologies, LLC

5/24

STORAGE AND DISPOSAL


DO NOT CONTAMINATE WATER, FOOD OR FEED BY STORAGE AND DISPOSAL. STORE IN COOL, DRY, VENTILATED AREA. STORE BELOW 50° C (122° F). KEEP PRODUCT OUT OF DIRECT SUNLIGHT. STORE SEPARATELY FROM WATER AND ACIDS. IF PACKAGE RUPTURES AND CONTENTS SPILL, DO NOT PERMIT CONTACT OF CONTENTS WITH ORGANIC MATERIALS (FOR EXAMPLE: CLOTHING OR COMBUSTIBLE MATERIALS) OR ACIDS. PESTICIDE WASTES ARE TOXIC. IMPROPER DISPOSAL OF EXCESS DRY PESTICIDE IS A VIOLATION OF FEDERAL LAW. IF THIS PRODUCT CANNOT BE USED ACCORDING TO LABEL INSTRUCTIONS, CONTACT YOUR STATE PESTICIDE OR ENVIRONMENTAL CONTROL AGENCY, OR THE HAZARDOUS WASTE REPRESENTATIVE AT THE NEAREST EPA REGIONAL OFFICE FOR GUIDANCE. NONREFILLABLE CONTAINER. DO NOT REUSE OR REFILL THIS CONTAINER. COMPLETELY EMPTY ACTIVATED SOLUTION IN POUCH INTO APPLICATION EQUIPMENT. OFFER FOR RECYCLING, IF AVAILABLE, OR DISPOSE OF EMPTY POUCH IN A SANITARY LANDFILL OR BY INCINERATION, OR, IF ALLOWED BY STATE AND LOCAL AUTHORITIES, BY BURNING. IF BURNED, STAY OUT OF SMOKE.

Warranty Statement: The Company warrants the product to be free from defects in material and workmanship. THE COMPANY MAKES NO WARRANTY THAT THE GOODS SHALL BE MERCHANTABILITY. THE COMPANY MAKES NO WARRANTY, EXPRESSED OR IMPLIED, EXCEPT SUCH AS IS EXPRESSLY SET FORTH HEREIN. The Company shall not be liable for any incidental or consequential damages for any breach of warranty. The Company's liability for any breach of warranty shall be limited to the purchase price of the product.

When used as directed, on hard, non-porous surfaces (e.g., stainless steel, brass, glass, vinyl, PVC, polypropylene), this product is an effective sanitizer, disinfectant, virucide*, fungicide, algacide, general-purpose antimicrobial and cleaner for use in a wide range of applications, including but not limited to: hospitals; medical & veterinary facilities; pharmaceutical production facilities, including equipment (e.g., ultracentrifuges); wineries, breweries, and beverage / bottling plants; laboratories and other clinical settings; potable and non-potable water systems and attendant equipment & tubing; restaurants and food processing plants; and greenhouses/horticultural settings. Heavily soiled surfaces must be pre-cleaned prior to treatment. Apply by mop, sponge, or sprayer, ensuring visible wetness for times specified for these applications, or apply through immersion or clean-in-place application. Wear a NIOSH/MHSA-approved respirator appropriate for chlorine dioxide when using a high-pressurized sprayer and under other circumstances detailed in the Technical Bulletin.

DIRECTIONS FOR USE: IT IS A VIOLATION OF FEDERAL LAW TO USE THIS PRODUCT IN A MANNER INCONSISTENT WITH THE LABELING. READ THE ENTIRE LABEL AND USE STRICTLY IN ACCORDANCE WITH PRECAUTIONARY STATEMENTS AND USE.

1. Fill the Selectocide® Pouch 200MG pouch with tap water (2 liters) to generate the chlorine dioxide solution.
2. WAIT AT LEAST 1 HOUR BEFORE USE TO ENSURE SOLUTION REACHES FULL STRENGTH AT 100 PPM.
3. Shake gently before use. Direct spout away from face when opening, work in well-ventilated area, and avoid inhaling fumes. Wear protective gloves if hands will come in contact with activated solution during dilution or application. In order to generate 500ppm stock solution, fill pouch with tap water (0.4 liters) and wait at least 6 hours before use to ensure solution reaches its full strength. Follow instructions for dilution using dilution tables in label and technical bulletin.
4. See Technical Bulletin for recommendations regarding dilutions and contact times for specific applications. Before use, verify concentration using *Selective Micro® Chlorine Dioxide Test Strips* to ensure appropriate concentration (see Technical Bulletin for directions if *Test Strips* indicate lower-than-desired concentration).
5. Activate prior to expiration date stamped on pouch. If solution in pouch will not be used up within 48 hours of activation, transfer unused solution to a dark, oxidation-resistant closed or sealed container; store dilutions of solution in a sealed container of the same type (see Tech Bulletin for container details). Store original or diluted solutions in cool place out of direct sunlight (do not store in refrigerator dedicated to food storage). Record activation date and concentration on stick-on label shipped with pouches, and affix to pouch or storage container. Use solution and/or subsequent dilutions within 15 days of activating pouch.



USE THE FOLLOWING GENERAL DILUTION INSTRUCTIONS

General Dilution Instructions: All dilutions begin with a solution at a nominal concentration of 100 ppm, except when the product is activated directly to strength of stock solution (see technical bulletin). Except where otherwise directed, or for other use concentrations (see technical bulletin), use the following dilution instructions to achieve the use concentration indicated:

To Achieve Use Concentration of:	Use Dilution Device or Sprayer With a Dilution Ratio of:
50 ppm	1:2 (one part 100 ppm solution to 1 parts water)
20 ppm	1:5 (one part 100 ppm solution to 4 parts water)
5 ppm	1:20 (one part 100 ppm solution to 19 parts water)
0.25 ppm	1:400 (one part 100 ppm solution to 399 parts water)

Sanitizer for Hard, Non-Porous, Food-Contact Surfaces, for Hard, Non-Porous, Non-Food-Contact Surfaces. Disinfectant or Virucide* For Hard, Non-Porous Surfaces, Disinfectant for Clean-in-Place Applications for Potable Water Systems, Antimicrobial and General Cleaning Applications for Potable Water Systems, Antimicrobial Applications for Non-Potable Water Systems in Horticultural settings, General disinfectant, sanitizer, algacide and fungicide for horticultural and greenhouse applications, Fruit and Vegetable Wash to Extend Freshness and Shelf-Life, Antimicrobial Applications to control the buildup of microbes in process waters for Fruit and vegetable rinse and associated tanks, flumes, and lines, Antimicrobial Treatment for Poultry Drinking Water, Sanitizing final rinse of pre-cleaned or new returnable or non-returnable containers, Antimicrobial and General Cleaning uses for non-potable water applications involving recirculating Water systems (e.g., cooling towers, paper mills, and decorative or ornamental fountains).

Please reference Master Label Technical Bulletin for Detailed Use Patterns and Dilution Rates.



Selective Micro Technologies

6/28

Selectrocide® - POUCH 200MG -

Technical Bulletin

Disinfectant/Sanitizer/Virucide*

Fungicide/Algaecide/Slimicide/Deodorizer

EPA Registration No. 74986-4

EPA Establishment No. 071441-OH-004

Activate *Selectrocide® Pouch 200MG* according to "Directions for Use" on pouch label. One pouch, activated as directed, contains two (2) liters of chlorine dioxide solution at a concentration of 100 ppm. Shake pouch gently before use, and prepare diluted solutions using the table below.

Dilution Instructions For: *Selectrocide® Pouch 200MG*

To Achieve Use Concentration of:	Use Dilution Device or Sprayer With a Dilution Ratio of:
50 ppm	1:2 (one part 100 ppm solution to 1 parts water)
20 ppm	1:5 (one part 100 ppm solution to 4 parts water)
5 ppm	1:20 (one part 100 ppm solution to 19 parts water)
0.25 ppm	1:400 (one part 100 ppm solution to 399 parts water)

Check concentration of solution using *Selective Micro® Chlorine Dioxide Test Strips*.
(See box on following page for instructions if check indicates concentration lower than desired)
Record activation date and concentration on stick-on label and affix to storage container.

Use solution within 15 days of activation.

Storage: Store unused solution according to "Directions for Use" on pouch label.
Transfer unused solution from pouch to approved storage container within 48 hours of activation.
After use, dispose of pouches according to disposal instructions on pouch label.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.
NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com
4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610
Technical Bulletin: 425-12445-007 (Revised 3-12)



DURING USE (DILUTING, APPLYING, OR WORKING WITH ACTIVATED PRODUCT):

1. Always work in well-ventilated area and avoid inhaling fumes of activated solution.
2. Wear protective gloves if hands will come in contact with activated solution.
3. Respiratory protection is not required under the limited exposure conditions of most normal use patterns. However, wear a NIOSH/MSHA-approved respirator under the following conditions:
 - a. when applying activated solution with a high-pressure sprayer
 - b. when working with the activated solution for an extended period of time in a closed facility or in a poorly-ventilated area
 - c. when normal workshift duties entail uninterrupted periods of applying the activated solution with mop, sponge, or sprayer
 - d. if OSHA inhalation exposure limits are reached or exceeded (see MSDS).
4. Do not use product in a manner inconsistent with the label.

IF TEST STRIPS INDICATE CONCENTRATION (PPM) LOWER THAN DESIRED:

3. Check expiration date on *Test Strips* container. If expired, then recheck using a fresh *Test Strip* from a container that has not reached its expiration date.
4. If the original container has not expired OR if the recheck indicates a lower-than-desired concentration, THEN DO ONE OF THE FOLLOWING:
 - 2a. If the application solution was prepared directly to the end-concentration (not diluted from a higher concentration); discard the solution and activate a fresh (unused) Selectocide® Pouch 200MG. Recheck concentration after waiting the prescribed time to activation.

OR

 - 2b. If the application solution was prepared by diluting a solution of higher concentration, add small amounts of the higher-concentration solution to the application solution—about 10% of the volume of the application solution at a time—until the *Selective Micro® Chlorine Dioxide Test Strip* indicates the desired concentration. Stir or mix the solution gently after each addition. Use a fresh (unused) *Test Strip* for each test.

**RECOMMENDED SPECIFICATIONS FOR CONTAINERS
USED WITH SELECTIVE MICRO PRODUCTS**

FOR USE IN GENERATING OR STORING ACTIVATED SOLUTIONS

- The container should be—or be comparable to—a UN-approved, liquid-resealable containment incorporating a gasket-sealing surface and locking mechanism.
- Construction should be of dark or opaque/UV-blocking (preferred) oxidation-resistant plastic or glass. Some materials recommended include:
 - High Density Polyethylene (HDPE)
 - Polypropylene (PP)
 - Polyethylene Terephthalate (PET)(PETE)
 - Polyvinyl Chloride (PVC)
 - Polycarbonate (PC)
 - Glass (UV-blocking preferred)
 - Gasket materials; silicone, viton or EPDM

Users without containers comparable to the above may contact Selective Micro Technologies for recommendations or to purchase containers for their applications.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

ATCC (OR OTHER) DESIGNATIONS FOR PATHOGENIC ORGANISMS
LISTED ON THE LABELS OF REGISTERED SELECTOCIDE PRODUCTS

—Always Consult Label to Verify Concentrations and Contact Times—

Bacteria (disinfection claims) 100 ppm/10-minute contact time

<i>Pseudomonas aeruginosa</i>	ATCC 15442
<i>Staphylococcus aureus</i>	ATCC 6538
<i>Salmonella enterica (choleraesuis)</i>	ATCC 10708
Methicillin-resistant <i>Staphylococcus aureus</i> (MRSA)	ATCC 33592
Vancomycin-resistant <i>Enterococcus faecalis</i> (VRE)	ATCC 51299
<i>Candida albicans</i>	ATCC 10231
<i>Trichophyton mentagrophytes</i>	ATCC 9533
<i>Listeria monocytogenes</i>	ATCC 19111
<i>Klebsiella pneumonia</i>	ATCC 4352

Bacteria (disinfection claims) for 50 ppm/20-minute contact time for clean-in-place applications

<i>Pseudomonas aeruginosa</i>	ATCC 15442
<i>Staphylococcus aureus</i>	ATCC 6538
<i>Salmonella enterica (choleraesuis)</i>	ATCC 10708
Methicillin-resistant <i>Staphylococcus aureus</i> (MRSA)	ATCC 33592
Vancomycin-resistant <i>Enterococcus faecalis</i> (VRE)	ATCC 51299
<i>Candida albicans</i>	ATCC 10231

***Viruses (virucidal claims at 100 ppm/10-minute contact time)**

<i>Coronavirus</i>	ATCC VR-740, Strain 229E
<i>Feline Calicivirus</i>	ATCC VR-782, Strain F-9
<i>Hepatitis A virus</i>	Strain HM-175
<i>Human Immunodeficiency Virus type 1 (HIV-1)</i>	Strain HTLV-III _B
<i>Poliovirus-1</i>	ATCC VR-1000, Strain Bgrghilde
<i>Rotavirus</i>	Strain WA
<i>Influenza-A virus</i>	ATCC VR-544, Strain Hong Kong
<i>Rhinovirus type 37</i>	ATCC VR-1147, Strain 151-1
<i>Canine Parvovirus</i>	ATCC VR-2017, Strain Cornell
<i>Adenovirus type 5</i>	ATCC VR-5; Strain Adenoid 75
<i>Herpes Simplex virus type 2</i>	ATCC VR-734, Strain G
<i>Vaccinia virus</i>	ATCC VR-119, Strain WR
<i>Norovirus (feline calicivirus surrogate)</i>	ATCC VR-782, Strain F-9
Pandemic 2009 H1N1 Influenza A virus	Reference <i>Influenza-A virus</i> (above)

Bacteria (sanitizer claim for hard, non-porous food contact surfaces) 5 ppm/1-minute contact time

<i>Staphylococcus aureus</i>	ATCC 6538
<i>Escherichia Coli</i>	ATCC 11229
<i>Escherichia coli O157:H7</i>	ATCC 43895
<i>Salmonella typhimurium</i> (MDRS)	CI 01005 (University of Maryland)

Bacteria (sanitizer claim for hard, non-porous non-food contact surfaces) 20 ppm/5-minute contact time

<i>Staphylococcus aureus</i>	ATCC 6538
<i>Klebsiella pneumonia</i>	ATCC 4352
<i>Listeria monocytogenes</i>	ATCC 1911

The information and instructions in this Technical Bulletin should not be confused with
nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com

4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610

Technical Bulletin: 425-12445-007 (Revised 3-12)

GENERAL USES

A. SANITIZER

FOR HARD, NON-POROUS FOOD CONTACT SURFACES

As a sanitizer for stainless steel and other hard, non-porous food contact surfaces such as tanks, transfer lines and other food processing equipment in food processing plants such as poultry, fish & meat and in restaurants, dairies, beverage and bottling plants, breweries, wineries and commissaries:

8. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label.
9. Remove all gross food particles and soil prior to sanitizing using a pre-flush, pre-scrape or pre-soak treatment.
10. Clean tank, line or surface thoroughly using a suitable detergent and rinse with clean, potable water before sanitizing.
11. Prepare a 5 ppm solution in accordance with instructions above **OR** use the undiluted contents of the activated Selectocide® Pouch 200MG pouch with a 1:20 dilution device (one part activated solution to 19 parts water).
12. To apply: spray, mop, sponge or swab surfaces **OR** fill, flush, immerse or circulate in tanks, lines, and equipment, ensuring the target surfaces remain visibly wet for at least one minute. When applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide.
13. After sanitizing, allow surfaces or equipment to air dry. Do not reuse solution. Do not rinse sanitized surface.
14. Dispose of pouch according to instructions on pouch label.

FOR HARD, NON-POROUS, NON-FOOD CONTACT SURFACES

As a sanitizer for non-porous, non-food contact surfaces and equipment such as sealed concrete and sealed, finished wood, backsplashes, counter tops, stainless steel or hard-surface equipment, glazed tile floors, walls, and ceilings:

1. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label.
2. Clean all surfaces thoroughly with a suitable detergent and rinse with water prior to sanitizing.
7. Prepare a 20 ppm solution in accordance with instructions above **OR** use the undiluted contents of the activated Selectocide® Pouch 200MG pouch with a 1:5 dilution device (one part activated solution to 4 parts water).
8. To apply: spray, mop or sponge the 20 ppm solution onto the surfaces to be sanitized, ensuring the target surfaces remain visibly wet for at least five minutes. When applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide.
9. After sanitizing, allow surfaces or equipment to air dry. Do not reuse solution. Do not rinse sanitized surfaces.
10. Dispose of pouch according to instructions on pouch label.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com

4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610

Technical Bulletin: 425-12445-007 (Revised 3-12)

B. DISINFECTANT

To disinfect stainless steel and other hard, non-porous surfaces such as tanks, transfer lines and other food processing equipment in food processing plants such as poultry, fish & meat and in restaurants, dairies, beverage and bottling plants, breweries, wineries and commissaries and to disinfect walls, floors and ceilings

8. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
9. Remove all gross food particles and soil prior to disinfecting using a pre-flush, pre-scrape or pre-soak treatment.
10. Clean tank, line or surface thoroughly using a suitable detergent and rinse with clean, potable water before disinfecting.
11. To apply: spray, mop, sponge or swab surfaces **OR** fill, flush, immerse or circulate in tanks, lines, and equipment, ensuring the target surfaces remain visibly wet for at least ten (10) minutes. When applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide.
12. After disinfecting allow surfaces or equipment to air dry. Do not reuse solution. Do not rinse disinfected surfaces.
13. Dispose of pouch according to instructions on pouch label.

DISINFECTANT USES IN MEDICAL AND DENTAL OFFICES, LABORATORIES, HOSPITALS, CLINICS, MORGUES AND INSTITUTIONS

This product is not to be used as a terminal sterilant/high-level disinfectant on any surface or instrument that (1) is introduced directly into the human body, either into or in contact with the blood stream or normally sterile areas of the body or (2) contacts intact mucous membranes but which does not ordinarily penetrate the blood barrier or otherwise enter normally sterile areas of the body. This product may be used to pre-clean or decontaminate critical or semi-critical medical devices prior to sterilization or high-level disinfection.

A. To disinfect non-porous, hard surfaces such as stainless steel or hard-surface equipment, glazed tile floors, walls, ceilings, stainless steel cold rooms and walk-in incubators:

7. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
8. Clean all surfaces thoroughly with a suitable detergent and rinse with water prior to disinfection.
9. Spray, mop or sponge the 100 ppm solution onto surfaces to be disinfected. All surfaces must remain visibly wet for at least ten (10) minutes. When applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide.
10. After disinfecting, allow surfaces or equipment to air dry. Do not reuse solution. Do not rinse disinfected surfaces.
11. Dispose of pouch according to instructions on pouch label.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com
4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610
Technical Bulletin: 425-12445-007 (Revised 3-12)

B. To disinfect equipment tops, bench tops, biological hoods, incubators, stainless steel equipment and instruments:

7. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
8. Clean all surfaces thoroughly with a suitable detergent and rinse with water prior to disinfection.
9. Spray, mop or sponge the 100 ppm solution onto surfaces to be disinfected. All surfaces must remain visibly wet for at least ten (10) minutes. When applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide.
10. After disinfecting, allow surfaces or equipment to air dry. Do not reuse solution. Do not rinse disinfected surfaces.
11. Dispose of pouch according to instructions on pouch label.

C. To disinfect commercial animal confinement facilities such as poultry houses, swine pens, calf barns and kennels:

11. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
12. Remove all animals and feed from facility to be disinfected.
13. Remove all litter and manure from floors, walls and surfaces of barns, pens, stalls, chutes and other structures occupied or traversed by animals.
14. Empty all troughs, racks and other feeding and watering appliances.

FOR GENERAL APPLICATION WITH SPRAYER:

15. With soap or detergent, thoroughly clean all surfaces and rinse with water.
16. Using a commercial sprayer, saturate all surfaces with the solution maintaining visible wetness for a period of at least ten (10) minutes. When applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide.
17. After treatment, ventilate buildings, coops or other enclosed spaces before reentering. Do not house poultry or employ equipment until treatment has been absorbed, set, or dried.

AS A DISINFECTING SOAK:

6. With soap or detergent, thoroughly clean halters, ropes or other types of equipment used in handling and restraining animals and forks, shovels and scrapers used in removing litter and manure. Rinse with water.
 7. Fill container or vat with 100 ppm solution, and immerse items for a period of at least ten (10) minutes.
 8. Discard solution in sanitary drain or as ordinary non-hazardous waste. Do not reuse solution.
18. Thoroughly scrub treated feed racks, troughs, automatic feeders, fountains and waterers with soap or detergent and rinse with potable water before reuse.
 19. Dispose of pouch according to instructions on pouch label.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.
NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

DISINFECTANT FOR BEVERAGE AND WATER SYSTEMS AND LINES

To disinfect lines, holding tanks and other equipment used in fountain drink or other beverage preparation, storage, transfer and dispensing operations or to disinfect the lines and storage tanks of potable water storage systems aboard aircraft, boats and RVs (clean-in-place applications):


Prior to disinfecting, clean tanks and flush thoroughly with clean, potable water

FOR A TEN (10) MINUTE OR LONGER DISINFECTION

6. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
7. **Fill tank completely with 100 ppm solution.** Run solution through transfer lines and appliances until green solution appears at the outlets. Top-off tank with solution. Circulate or let stand in tank and lines for at least ten (10) minutes.
8. Drain tanks and lines. Rinse with potable water.
9. Dispose of pouch(es) according to instructions on pouch label.

FOR A TWENTY (20) MINUTE OR LONGER DISINFECTION

6. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
7. Prepare a 50 ppm solution in accordance with instructions above **OR** use the undiluted contents of the activated Selectocide® Pouch 200MG pouch with a 1:1 dilution device (one part activated solution to one part water).
8. **Fill tank completely with 50 ppm solution.** Run solution through transfer lines and appliances until green solution appears at the outlets. Top-off tank with solution. Circulate or let stand in tank and lines for at least twenty (20) minutes.
9. Drain tanks and lines. Rinse with potable water.
10. Dispose of pouch(es) according to instructions on pouch label.



The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.
NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.



ANTIMICROBIAL AND GENERAL CLEANING APPLICATIONS FOR WATER LINES AND TANKS IN POTABLE WATER SYSTEMS

This product will reduce microbial populations in the potable water holding tanks and lines of recreational vehicles (RV) and boats; in marine and RV wastewater tanks and lines; and fountain drink or other beverage preparation, storage, transfer and dispensing lines and equipment, and in coolers, thermoses, plastic water bottles, and other water-storing and dispensing systems used for picnics, camping, and other recreational activities. In addition, it will clean, eliminate odors, and remove organic matter. These uses must be followed by a potable water rinse.

NOTE: If the tank system is cleaned frequently, then consider the level of contamination to be **low to moderate**. If the tank system is used heavily, notably fouled, cleaned irregularly, or going into or coming out of overwintering, then consider the tank(s) level of contamination to be **high**.

1. Based on the judged level of contamination (see box above), determine the number of pouches of Selectrocide® Pouch 200MG necessary to clean the drinking water system in accordance with the table below. Consider all interconnected tanks in the system as one. [For example: A system with two 80-gallon tanks has a total capacity of 160 gallons. At low to moderate contamination, use ten (10) Selectrocide® Pouch 200MG pouches; at high levels of contamination, use twenty (20) pouches.]
2. Activate the Selectrocide® Pouch 200MG (s) according to "Directions for Use" on pouch label.
3. Drain all water tanks completely. Then, refill tanks with water to approximately 10% of their capacity (for example, a 100-gallon tank should be filled with 10 gallons of water.)
4. After the one-hour activation time, add the contents from the number of pouches calculated in instruction 1 to the water tanks. **Do not add additional water. Do not refill tank. Close the tank.**
5. Circulate the diluted Selectrocide® Pouch 200MG solution through all lines and between tanks using the system's pumps.
6. Run approximately 30 ounces of the Selectrocide® Pouch 200MG solution through each outlet (faucet, shower etc.) and let the solution stand in the tanks and lines **OVERNIGHT**.
7. The next day, flush the Selectrocide® Pouch 200MG solution through all faucets and outlets until the tanks are empty.
8. Refill the tanks with rinse water to approximately 10% of their capacity (10 gallons per 100 gallons capacity).
9. Circulate the water and flush rinse water through all faucets and outlets until tanks are empty.
10. Tanks are now cleaned and can be refilled for use or left empty for storage.
11. Dispose of pouch(es) according to instructions on the pouch label.

HORTICULTURAL DISINFECTANT, SANITIZER, ALGAECIDE, FUNGICIDE AND SLIME REMOVER/INHIBITER

Treats/Controls/Inhibits: Algae (*Phormidium boneri*) and Fungi (*Penicillium digitatum*, *Botrytis sp.*, *Fusarium solani*, *Pythium aphanidermatum*, *Pythium irregulare*, *Fusarium oxysporum f. sp. basilicum* (Fob))

This product, when used as directed:

- (1) disinfects non-porous hard surfaces, pots, flats, flower buckets and cutting tools;
- (2) sanitizes non-porous hard surfaces, racks, stands, work areas, benches and cutting tools;
- (3) removes or inhibits (under continuous treatment) re-establishment of slime in irrigation/transfer lines and systems;
- (4) treats, controls and prevents build-ups of soil-borne plant diseases and other algae, fungi and attendant slimes on: soils used to grow nursery stocks, bedding plants, flowering plants and ornamentals; on cut flowers and other

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com

4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610

Technical Bulletin: 425-12445-007 (Revised 3-12)



cuttings, seedlings and seeds; and on and within greenhouse equipment and structures such as irrigation/transfer lines and systems, pots, floors, ventilation ducts and equipment, storage rooms, growing tables, evaporative coolers, plastics, benches and flower pots; and

(5) controls bacterial counts, maintains freshness, and extends shelf life for cut flowers.

NOTE: Do not use at concentrations higher than those recommended for each application. When applied directly to plants, seeds, cuttings or flowers as directed, Selectrocide® Pouch 200MG does not cause a adverse cosmetic effects, as testing has demonstrated. However, testing has not been performed on EVERY plant species, and users are advised to spot-test Selectrocide® Pouch 200MG before applying it widely.

Active solution may be irritating if breathed. If applying solution inside greenhouse or enclosed area using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide: after treatment, ventilate greenhouse before reentering.

A. To disinfect non-porous hard surfaces, including stainless steel, glazed tile, sealed concrete and sealed, finished wood used in horticultural applications:

- 6. Activate Selectrocide® Pouch 200MG according to "Directions for Use" on pouch label.
- 7. Pre-clean all surfaces prior to application of disinfectant solution. Sweep and remove all plant debris. Use power sprayer to wash all surfaces to remove loose dirt.
- 8. Prepare solutions in indicated concentrations and ensure surfaces are wetted and remain visibly wet for the times noted below in the instructions associated with the desired application. Dispose of pouch according to instructions on pouch label.

FOR WORK AREAS, BENCHES AND EVAPORATIVE COOLERS

- 9. Prepare a 100 ppm solution in accordance with the instructions above **OR** use the undiluted contents of the activated Selectrocide® Pouch 200MG solution with a 1:5 dilution device (one part activated solution to four parts water).
- 10. Spray or swab work area and bench surfaces before each work period and again after each planting is completed to help control the transfer of diseases. Spray or swab evaporative cooler surfaces, ensuring visible wetness for at least ten (10) minutes. When applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements. NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

FOR POTS, FLATS, FLOWER BUCKETS AND CUTTING TOOLS
FOR A TEN (10) MINUTE OR LONGER DISINFECTION

7. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
8. Brush or wash used pots and flats, and then soak in the 100 ppm solution for at least ten (10) minutes before reuse to help control transfer of diseases. Soak tools with 100 ppm solution for at least ten (10) minutes to help control the transfer of disease.
9. Discard solution in sanitary drain or as ordinary non-hazardous waste. Do not reuse solution.

At end of workday, dry and oil tools.

FOR A TWENTY (20) MINUTE OR LONGER DISINFECTION

7. Prepare a 50 ppm solution in accordance with the instructions above **OR** use the undiluted contents of the activated Selectocide® Pouch 200MG solution with a 1:1 dilution device (one part activated solution to one part water).
8. Brush or wash used pots and flats and then soak in the 50 ppm solution for at least twenty (20) minutes before reuse to help control transfer of diseases. Soak tools with 50 ppm solution for at least twenty (20) minutes to help control the transfer of disease.
9. Discard solution in sanitary drain or as ordinary non-hazardous waste. Do not reuse solution.

At end of workday, dry and oil tools.

B. To sanitize work area non-porous (non-food contact) hard surfaces, hard-surface benches, pots, flats, flower buckets and cutting tools:

6. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
7. Pre-clean all surfaces prior to application of sanitizing solution. Sweep and remove all plant debris. Use power sprayer to wash all surfaces to remove loose dirt.
8. Prepare a 20 ppm solution in accordance with the instructions above **OR** use the undiluted contents of the activated Selectocide® Pouch 200MG solution with a 1:5 dilution device (one part activated solution to 4 parts water).
9. Brush or wash used pots and flats then swab or soak in the 20 ppm solution for at least five (5) minutes before reuse to help control transfer of diseases. Spray, swab or soak tools with 20 ppm solution for at least five (5) minutes to help control the transfer of disease. Spray or swab work area and bench surfaces before each work period and again after each planting is completed to help control the transfer of diseases. If applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide. If soaking, discard solution in sanitary drain or as ordinary non-hazardous waste; do not reuse solution.
10. Dispose of pouch according to instructions on pouch label.

At end of workday, dry and oil tools

C. As a dip to control and suppress bacteria (*Erwinia chrysanthemi*), algae (such as *Phormidium boneri*) and fungi (such as *Penicillium digitatum*, *Botrytis sp.*, and *Fusarium solani*) on rooted and unrooted cuttings and cut flowers:

5. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
6. Prepare a 5 ppm solution in accordance with the instructions above **OR** use the undiluted contents of the activated Selectocide® Pouch 200MG solution with a 1:20 dilution device (one part activated solution to 19 parts water).

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com
 4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610
 Technical Bulletin: 425-12445-007 (Revised 3-12)



- 7. Briefly dip cuttings or cut flowers and ensure they remain visibly wet with solution for at least one minute.
- 8. Dispose of pouch according to instructions on pouch label.

D. As a dip or drench to control and suppress bacteria (*Erwinia chrysanthemi*), algae (*Phormidium boneri*) and fungi (*Penicillium digitatum*, *Botrytis sp.*, *Fusarium solani*, *Pythium aphanidermatum*, *Pythium irregulare*, *Fusarium oxysporum f. sp. Basilicum (Fob)*) in seed-bed soil and planting cubes:

- 5. Activate Selectroicide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
- 6. Prepare a 5 ppm solution in accordance with the instructions above **OR** use the undiluted contents of the activated Selectroicide® Pouch 200MG solution with a 1:20 dilution device (one part activated solution to 19 parts water).
- 7. Immerse or drench seed-bed soil or planting cubes and allow to remain visibly wet with solution for ten (10) minutes.
- 8. Dispose of pouch according to instructions on pouch label.

Soil or planting cubes can be seeded or planted immediately after treatment.

E. For removing slime and retarding its reemergence; for antimicrobial applications involving algae (*Phormidium boneri*) and fungi (*Penicillium digitatum*, *Botrytis sp.*, *Fusarium solani*, *Pythium aphanidermatum*, *Pythium irregulare*, *Fusarium oxysporum f. sp. Basilicum (Fob)*); and for continuous treatment to inhibit their re-establishment in irrigation systems, flood floors, flooded benches, misting systems, humidification systems, recycled water systems and capillary mats:

- 6. Activate Selectroicide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
- 7. Pre-clean all surfaces prior to application of disinfectant solution. Sweep and remove all plant debris. Use power sprayer to wash all surfaces to remove loose dirt.
- 8. Prepare solutions in indicated concentrations and ensure surfaces are wetted and remain visibly wet for the times or are applied continuously as noted below. Dispose of pouch according to instructions on pouch label.

AS AN INITIAL OR REMEDIAL TREATMENT TO DISINFECT WATER HOLDING TANKS AND LINES (CLEAN-IN-PLACE APPLICATION)

- 4. Flush tank thoroughly with clean water.
- 5. Prepare a 50 ppm solution in accordance with the directions above **OR** use the undiluted contents of the activated Selectroicide® Pouch 200MG solution with a 1:1 dilution device (one part activated solution to one part water).
- 6. Fill tank completely. Run solution through irrigation/transfer lines and appliances until green solution appears at the outlets. Top-off tank with solution. Circulate or let stand in tank and lines for at least twenty (20) minutes.
- 7. Drain tanks and lines, flush with clean water, and resume normal operation.

AS AN INITIAL OR REMEDIAL TREATMENT TO DISINFECT AND REMOVE SLIME, ALGAE AND FUNGI FROM WATER HOLDING TANKS AND IRRIGATION/TRANSFER LINES (CLEAN-IN-PLACE APPLICATION)

- 4. Flush tank thoroughly with clean water.
- 5. Prepare a 50 ppm solution in accordance with the directions above **OR** use the undiluted contents of the activated Selectroicide® Pouch 200MG solution with a 1:1 dilution device (one part activated solution to one part water).
- 6. Fill tank completely. Run solution through irrigation/transfer lines and appliances until green solution appears at the outlets. Top-off tank with solution. Circulate or let stand in tank and lines overnight (12 hours).
- 7. Drain tanks and lines, flush with clean water, and resume normal operation.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

FOR CONTINUOUS TREATMENT TO INHIBIT THE RE-ESTABLISHMENT OF SLIME, ALGAE, AND FUNGI

9. Dilute the 500 ppm solution to 0.25 ppm by adding one part 100 ppm solution to 399 parts water.
10. Use the 0.25 ppm solution to operate the water system following normal application procedures.

NOTE: Use ultra low-range *Selective Micro® Chlorine Dioxide Test Strips* to verify concentration at downstream production points. Organic loads vary across water supplies, and will influence injection level necessary to ensure 0.25 ppm concentrations at emitter hoses, mist nozzles, and drip tubes.

F. As an algaecide and fungicide for treating, preventing, suppressing and controlling horticultural diseases on hard, non-porous surfaces in commercial greenhouses, garden centers and nurseries:

5. Activate Selectrocide® Pouch 200MG according to "Directions for Use" on pouch label.
6. Pre-clean all non-plant surfaces prior to application of solution. Sweep and remove all plant debris. Use power sprayer to wash all surfaces to remove loose dirt.
7. Prepare solutions in indicated concentrations and ensure all surfaces are wetted and remain visibly wet for the times noted below.
8. Dispose of pouch according to instructions on pouch label.

AS AN INITIAL OR REMEDIAL TREATMENT TO KILL ALGAE AND FUNGI ON HARD NON-POROUS SURFACES ON EQUIPMENT, GREENHOUSE STRUCTURES, GLAZING, PLASTIC, BENCHES, WALKWAYS, FLOORS, WALLS, FAN BLADES, VENTILATION DUCTS, WATERING SYSTEMS, COOLERS AND STORAGE ROOMS:

5. Prepare a 5 ppm solution in accordance with the instructions above **OR** use the undiluted contents of the activated Selectrocide® Pouch 200MG solution with a 1:20 dilution device (one part activated solution to 19 parts water).
6. Apply solution with mop, sponge or sprayer. When applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide.
7. Visibly wet all surfaces and ensure the surfaces remain visibly wet for at least one hour.

Note: Heavy growths of algae or fungi may require scrubbing to remove dead growth.

AS A WEEKLY PREVENTATIVE TREATMENT TO KILL, CONTROL AND SUPPRESS FUNGI AND CONTROL AND SUPPRESS ALGAE ON HARD NON-POROUS SURFACES ON EQUIPMENT, GREENHOUSE STRUCTURES, GLAZING, PLASTIC, BENCHES, WALKWAYS, FLOORS, WALLS, FAN BLADES, VENTILATION DUCTS, WATERING SYSTEMS, COOLERS AND STORAGE ROOMS:

4. Prepare a 5 ppm solution in accordance with the instructions above **OR** use the undiluted contents of the activated Selectrocide® Pouch 200MG solution with a 1:20 dilution device (one part activated solution to 19 parts water).
5. Apply solution with mop, sponge or sprayer. When applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide. Visibly wet all surfaces and ensure the surfaces remain visibly wet for at least one hour (kill/cidal) and at least one minute (suppression).

G. As a dip to control and suppress bacteria (*Erwinia chrysanthemi*) on cuttings and cut flowers:

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.



1. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label.
2. Prepare a 5 ppm solution in accordance with the instructions above **OR** use the undiluted contents of the activated Selectocide® Pouch 200MG solution with a 1:20 dilution device (one part activated solution to 19 parts water).
3. Briefly dip cuttings or cut flowers and ensure they remain visibly wet with solution for at least one minute.
4. Dispose of pouch according to instructions on pouch label.

H. To maintain freshness and extend shelf-life for cut flowers:

5. Activate Selectocide® Pouch 200MG according to "Directions for Use" on pouch label.
6. Prepare a 5 ppm solution in accordance with the instructions above **OR** use the undiluted contents of the activated Selectocide® Pouch 200MG solution with a 1:20 dilution device (one part activated solution to 19 parts water).
7. Unbundle the flowers to preclude bunching, and place in vase on display or in cold storage in the 5 ppm solution of chlorine dioxide. Solution may include 2% sucrose.
8. Refresh solution every 24 hours.
9. Dispose of pouch according to instructions on pouch label.

TO EXTEND SHELF-LIFE AND FRESHNESS OF FRUITS AND VEGETABLES IN FOOD PROCESSING FACILITIES:

THIS PRODUCT WILL REDUCE CONCENTRATIONS OF SPOILAGE MICROBES ON RAW AGRICULTURAL COMMODITIES (RACS) INTENDED FOR COMMERCIAL FOOD PROCESSING.

1. Activate Selectocide® Pouch 200MG according to "Directions for Use" on the pouch label.
2. Wash and thoroughly rinse fruits and vegetables with clean, potable water.
3. Prepare a 5 ppm solution of activated Selectocide® Pouch 200MG **OR** use the 100 ppm solution with a 1:20 dilution device (one part 100 ppm solution to 19 parts water).
4. Apply to fruits and vegetables by: either immersing/dipping in a tank of 5 ppm solution for one minute **OR** using an application-specific sprayer (the industry standard fan or cone spray nozzle pattern) to cover all surfaces evenly with a 5 ppm spray. Replenish immersion solution at the rate of depletion; verify 5 ppm concentration using *Selective Micro® Chlorine Dioxide Test Strips*. Empty and wash immersion tanks with every shift change.
5. Follow application to fruits and vegetables with a potable water rinse or canning, blanching, or cooking.
6. Dispose of pouch according to instructions on pouch label.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

ANTIMICROBIAL APPLICATIONS TO CONTROL THE BUILDUP OF MICROBES IN PROCESS WATERS FOR FRUITS AND VEGETABLES AND ASSOCIATED TANKS, FLUMES, AND LINES

This product will inhibit microbial growth in water used to process fruits and vegetables. Appropriate for small-volume applications only; use *Selectrocide*® G-Series products for normal- and large-volume process water applications.

- NOTE:**
1. Replacement and replenishment intervals will vary with microbial challenge presented by fruits and vegetables treated. Selective Micro Technologies recommends a beginning concentration of 5 ppm, with adjustments to ensure a residual concentration between 0.25 and 5 ppm depending on microbial challenge and operation-unique factors.
 2. Apply chlorine dioxide solution continuously or intermittently to achieve a residual concentration level between 0.25 – 5.0 ppm.
 3. Regularly confirm concentration of process water using *Selective Micro*® Chlorine Dioxide Test Strips or other measurement means (e.g., Oxidation Reduction Potential [ORP] metering).

2. At regular intervals or before beginning a shift, clean tanks, flumes, and lines using normal procedures, and follow with potable water rinse. [In conditions of severe microbial accumulation (or when slime is visible), it is advisable to treat the thoroughly cleaned system with an antimicrobial treatment before returning the system to normal operation. See *Selectrocide*®'s "Antimicrobial and General Cleaning Applications for Water Lines and Tanks in Potable Water Systems" for recommendations on cleaning tanks that are contaminated severely.]
2. Determine the number of *Selectrocide*® Pouch 200MG pouches necessary based on the capacity of the tank or system, anticipated replenishment/replacement cycle based on expected microbial loads, and specific application method—once-through or recycled. The optimal concentration necessary to ensure a residual concentration of between 0.25 and 5.0 ppm will vary across operations.

For "once-through" process designs, generate *Selectrocide*® Pouch 200MG directly to the desired end-concentration in the system's operating tank (recommended) OR generate stock 100 ppm external to the tank and meter the stock solution in adequate volume to raise the volumes of process water to the desired concentration via mechanical injection (recommended) or by batch-loading.

For "recycle" process designs, generate stock 100 ppm solution external to the tank and inject activated solution in sufficient volume to raise the process water to the desired concentration via mechanical injection (recommended) or by batch-loading.

Consult pages 1-2 of this Technical Bulletin for dilution instructions, or scale to application using the table below, which presents, as a starting point, the total volume of stock 5 ppm solution generated using multiple pouches of *Selectrocide*® Pouch 200MG. Because the volume of 5 ppm solution achievable using the *Selectrocide*® Pouch 200MG is small, this product will be useful only for the smallest-volume applications. Use *Selectrocide*® G-Series products for normal- and large-volume process water applications.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com
4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610
Technical Bulletin: 425-12445-007 (Revised 3-12)

**VOLUME OF 5 PPM SOLUTION USING
SELECTROCID® POUCH 200MG POUCHES**

Number of Required Pouches of Selectrocid® Pouch 200MG	Volume of Water Specified To Generate 100 ppm Stock Solution	Volume of 5 ppm Solution Created Using a Single Selectrocid® Pouch	
		Liters	Gallons ¹
1	2	40	10
2	4	80	20
3	6	160	30
4	8	320	45
5	10	640	55

¹ rounded to nearest 5 gallons

3. Activate *Selectrocid® Pouch 200MG* according to "Directions for Use" on package label.
4. Prepare a 5 ppm solution of activated *Selectrocid® Pouch 200MG* directly in accordance with instructions above OR prepare a 100 ppm solution with any of the G-series products and use a 1:20 dilution device (one part 100 ppm solution to 19 parts water) to achieve target concentration of 5 ppm.
5. Verify concentration of process solution using *Selective Micro® Chlorine Dioxide Test Strips* or other appropriate means. Adjust concentration by adding additional water if the concentration is above 5 ppm or by adding additional concentrate if below 5 ppm (or below desired concentration between 0.25 and 5.0 ppm).
6. Cover or enclose containers holding solution, and operate normally.
7. Check concentration at regular intervals using test strips or other means to ensure target concentration is maintained. Replenish solution as necessary to maintain target concentration.
8. At desired intervals, drain system, clean as necessary, and refill with freshly-activated solution.
9. Dispose of pouch according to instructions on pouch label.

ANTIMICROBIAL TREATMENT FOR POULTRY DRINKING WATER

This product will help control microorganisms in drinking water intended for poultry.

A. For systems that use automatic, on-demand metering/injection systems designed primarily for poultry (i.e., systems employing nipples or drip wells as the final water delivery device/method, usually situated in enclosed or protected structures):

1. Activate *Selectrocid® Pouch 200MG* according to "Directions for Use" on product label.
2. If activation vessel is different from feeder tank, transfer stock solution (100 ppm) to feeder tank. To maintain concentration, ensure that feeder tank is covered.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com
 4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610
 Technical Bulletin: 425-12445-007 (Revised 3-12)



3. Operate system according to standard operating protocol, using a 1:20 injection device (one part solution to 19 parts water) for a concentration of 5 ppm.
4. Confirm concentrations of stock solution (100 ppm) and end-use solution up to 5 ppm but not less than an application concentration sufficient to ensure a residual concentration of 0.25 ppm using *Selective Micro® Chlorine Dioxide Test Strips*.
5. Dispose of pouch according to instructions on pouch label.

Note: Clean and remove accumulations of organic matter in delivery lines on a regular basis. (See, for example, label and technical bulletin instructions for this product under the heading "Antimicrobial and General Cleaning Applications for Potable Water Systems")

B. For trough-based systems.

Use products from the *Selectocide® G-Series* for these large-volume applications.

SANITIZING FINAL RINSE OF PRE-CLEANED OR NEW RETURNABLE OR NON-RETURNABLE CONTAINERS...

This product may be used as a final sanitizing rinse for plastic, glass or metal returnable and non-returnable bottles, cans, caps, kegs, and beverage containers.

6. Activate *Selectocide® Pouch 200MG* according to "Directions for Use" on pouch label.
7. Wash bottles, cans or containers with detergent or cleaning solution and rinse with potable water.
8. Starting with the 100 ppm solution, use a 30:100 dilution device (thirty parts 100 ppm solution to 70 parts water) to achieve an application concentration of 30 ppm. The table below presents the number of *Selectocide® Pouch 200MG* pouches necessary to product the associated volume of 30 ppm application solution.

VOLUME OF 30 PPM SOLUTION USING SELECTOCIDE® POUCH 200MG POUCHES

Number of Required Pouches of <i>Selectocide® Pouch 200MG</i>	Volume of Water Specified To Generate 100 ppm Stock Solution	Volume of 30 ppm Solution Created Using a Single <i>Selectocide® Pouch 200MG</i>	
	Liters	Liters	Gallons
1	2	7	1.7
2	4	13	3.3
3	6	27	5.0
4	8	53	7.5
5	10	107	9.2

1 Rounded to nearest liter or tenths of gallon

9. To apply: rinse interior and exterior surfaces with the 30 ppm solutions by spraying, sponging, swabbing, or swirling, or immersing in a manner that ensures the target surfaces become visibly wet for a contact time of 30 seconds (including

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.



drying time). (If applying these solutions using a high-pressure sprayer, wear a NIOSH/MSHA-approved respirator appropriate for chlorine dioxide).

- 10. Allow to drain dry.

NOTE: Use products from the *Selectrocide® G-Series* for larger-volume applications.

**ANTIMICROBIAL AND GENERAL CLEANING USES FOR
NON-POTABLE WATER APPLICATIONS INVOLVING
RECIRCULATING WATER SYSTEMS (E.G., COOLING TOWERS,
PAPER MILLS, AND DECORATIVE OR ORNAMENTAL FOUNTAINS)**

This product will help remove, control and inhibit reemergence of slimes, algae, fungi, and other organic buildups in recirculating cooling water systems, including cooling towers and decorative or ornamental fountains. It can be used as a periodic treatment or during continuous operations in antimicrobial applications involving algae, fungi or bacteria.

- 9. Activate *Selectrocide® Pouch 200MG* according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
- 10. Where possible, pre-clean surfaces prior to application. Flush tanks or water system with clean water.
- 11. Apply/add the 100-ppm solution to the tank water or water stream at a point in the system in a manner which minimizes turbulence and exposure to the air.
- 12. Dispose of pouch according to instructions on pouch label.

**AS AN INITIAL OR REMEDIAL TREATMENT FOR RECIRCULATING COOLING WATER SYSTEMS,
WATER HOLDING TANKS AND DECORATIVE AND ORNAMENTAL FOUNTAINS**

- 13. For each 55 gallons of cooling or fountain water add the contents of five single pouches of activated *Selectrocide® Pouch 200MG* solution (2 liters at 100 ppm) to achieve a 5 ppm residual chlorine dioxide level. Circulate water in normal operation of the system.
- 14. Check residual chlorine dioxide concentration using *Selective Micro® Chlorine Dioxide Test Strips*. If residual chlorine dioxide concentration is below 5 ppm, add additional 500 ppm solution until solution reaches 5 ppm; verify with *Test Strips*.
- 15. Repeat daily until desired results are achieved.

FOR CONTINUOUS TREATMENT TO INHIBIT THE RE-ESTABLISHMENT OF SLIME, ALGAE, OR FUNGI

- 6. For each 550 gallons of cooling or fountain water add the contents of five single pouches of activated *Selectrocide® Pouch 200MG* solution (2 liters at 100 ppm) to achieve a residual chlorine dioxide concentration of approximately 0.5 ppm. Circulate water in normal operation of the system.
- 7. Check residual chlorine dioxide concentration using *Selective Micro® Chlorine Dioxide Test Strips*. If residual chlorine dioxide concentration falls below 0.1 ppm, add more 100 ppm solution (about 5 gallons of the 100 ppm solution for each 1,000 gallons of cooling or fountain water) to increase the residual chlorine dioxide concentration to about 0.5 ppm. Verify concentration with *Test Strips*.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.



INSTRUCTIONS WHEN USING A DOSING PUMP AS AN INITIAL OR REMEDIAL TREATMENT FOR RECIRCULATING COOLING WATER SYSTEMS, WATER HOLDING TANKS AND DECORATIVE AND ORNAMENTAL FOUNTAINS


- 9. For each 55 gallons of cooling or fountain water add the contents of five single pouches of activated *Selectrocide® Pouch 200MG* solution (2 liters at 100 ppm) to achieve a 5 ppm residual chlorine dioxide level. Circulate water in normal operation of the system.
- 10. Check residual chlorine dioxide concentration using *Selective Micro® Chlorine Dioxide Test Strips*. If residual chlorine dioxide concentration is below 5 ppm, add additional 500 ppm solution until solution reaches 5 ppm; verify with *Test Strips*.
- 11. Repeat daily until desired results are achieved.

INSTRUCTIONS WHEN USING A DOSING PUMP FOR CONTINUOUS TREATMENT TO INHIBIT THE RE-ESTABLISHMENT OF SLIME, ALGAE, OR FUNGI

- 6. Set the dosing pump to achieve a continuous concentration of chlorine dioxide between 0.25 ppm and 0.5 ppm. In order to maintain this concentration and the appropriate dosing, consider the volume of water in the system, half-life (makeup/blowdown rate), evaporative rate and windage loss of the system.
- 7. Check residual chlorine dioxide concentration using *Selective Micro® Chlorine Dioxide Test Strips*. If residual chlorine dioxide concentration falls below 0.25 ppm, increase the dosage rate.

FOR PERIODIC TREATMENT TO INHIBIT THE RE-ESTABLISHMENT OF SLIME, ALGAE, OR FUNGI

- 8. For each 550 gallons of cooling or fountain water add the contents of five single pouches of activated *Selectrocide® Pouch 200MG* solution (2 liters at 100 ppm) to achieve approximately 0.5 ppm residual chlorine dioxide concentration. Circulate water in normal operation of the system. Check residual chlorine dioxide concentration using *Selective Micro® Chlorine Dioxide Test Strips*.
- 9. Repeat weekly or on first indications of increased slime, algae or fungi.



The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements. NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com
4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610
Technical Bulletin: 425-12445-007 (Revised 3-12)

DISINFECTION, SANITIZING, ANTIMICROBIAL AND GENERAL CLEANING APPLICATIONS FOR WINERIES

This product will disinfect, sanitize, and clean winemaking equipment and environmental surfaces in wineries. It is effective against microbes and spoilage organisms on all non-porous surfaces including: picking bins, crushers, transfer lines/hoses/pipes, tanks, drains, pumps, presses, de-stemmers, sealed concrete floors and walls, steel cutting boards/surfaces, sumps, valves and tri-clover fittings, pruning shears, and steel wine barrels.

- NOTE: 1. For additional information on label applications or to discuss other winery-specific application issues, contact Selective Micro Technologies' service personnel.
2. This product does not produce Trichloroanisol (TCA) or precursor Trichlorophenol (TCP) by chemical reaction in red wine or in cooperage oak, and therefore does not contribute to the off odors associated with the former.

A. Disinfecting and sanitizing applications for winery equipment and environmental surfaces (including all non-porous materials and surfaces, such as transfer hoses and pipes, and other items listed above):

3. Activate Selectroicide® Pouch 200MG according to "Directions for Use" on pouch label to prepare a 100 ppm solution in accordance with instructions.
4. Disinfecting Applications. For disinfecting applications, prepare a 100 ppm solution of activated Selectroicide® Pouch 200MG.
Sanitizing Applications on hard, food-contact surfaces. For sanitizing applications on hard, food-contact surfaces, prepare a 5 ppm solution of activated Selectroicide® Pouch 200MG directly in accordance with instructions above OR prepare a 100 ppm solution of Selectroicide® Pouch 200MG and use a 1:20 dilution device (one part 500 ppm solution to 19 parts water).
Sanitizing Applications on hard, non-food-contact surfaces. For sanitizing applications on hard, non-food-contact surfaces, prepare a 20 ppm solution of activated Selectroicide® Pouch 200MG directly in accordance with instructions above OR prepare a 100 ppm solution of Selectroicide® Pouch 200MG and use a 1:5 dilution device (one part 500 ppm solution to 4 parts water).
3. Apply to target surfaces with mop, sponge, or spray OR fill, flush, immerse or circulate in tanks, lines and equipment, ensuring surfaces remain visibly wet for the following contact times:
 - Disinfection (100 ppm): 10 minutes
 - Sanitizing hard food-contact surfaces (5 ppm): 1 minute
 - Sanitizing hard non-food contact surfaces (20 ppm): 5 minutes
4. Dispose of pouch according to instructions on pouch label.

B. For sanitizing and cleaning tanks and associated connections, pipes, and hoses:

Use products from the Selectroicide® G-Series for these large-volume applications.

The information and instructions in this Technical Bulletin should not be confused with nor followed in violation of applicable laws, regulations, rules, or insurance requirements.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.

Selective Micro Technologies www.selectivemicro.com
4449 Easton Way 2nd Floor, Columbus, OH 43219 Phone 614-934-1339 FAX 614-934-1610
Technical Bulletin: 425-12445-007 (Revised 3-12)